

# District School Board of Pasco County

## Bid Recommendation

<b>Bid Title</b>	Heat Pumps A/C Maintenance Department		<b>Number of Vendors Notified</b>	295
<b>Bid Number</b>	08-031-LR		<b>Number of Bids Distributed</b>	28
<b>Date Solicited</b>	June 22, 2007		<b>Number of Vendors Bidding</b>	2
<b>Date Opened</b>	July 17, 2007		<b>Number of Vendors Not Bidding</b>	0
<b>Date Board Presentation</b>	August 21, 2007		<b>Funding Source</b>	N/A
<b>Total Savings</b>	N/A		<b>Grand Total of Bid</b>	<b>REJECT</b>

**Recommendation:**

Recommend rejection of only bid meeting specifications, Carroll Air Systems, as their bid prices exceed the budget. Request permission to obtain written quotes when needed.

**Term of Contract:**

This bid is for heat pump air conditioners “as needed” by the Maintenance Department for use throughout the District. This is a three-year bid renewable annually based upon mutual agreement of both parties.

**Notations and Exceptions:**

Recommend rejection of lower bid from Tampa Bay Trane for failure to meet the written specifications for automatic fresh air damper and stainless steel drain pans. The bid from Carroll Air Systems was considered too high and over budget and not to be in the best interest of the District. Maintenance will obtain written quotes on an “as needed” basis.

Offers from the vendors listed herein are the only offers received timely as of the above opening date and time. All other offers submitted in response to this solicitation, if any, are hereby rejected as late.

**Bids Evaluated By:**

Gerry Brown, Director, Maintenance Department  
Phil Laycock, Crew Chief, Maintenance Department

**Bids Prepared By:**

Laurie Roberts, CPPB, Buyer, Purchasing Department

**Reviewed and Authorized By:**

Kendra Goodman, CPPB, Purchasing Agent

DISTRICT SCHOOL BOARD OF PASCO COUNTY BID TABULATION

DATE OF OPENING: July 17, 2007 @ 2:30 P.M.		Carroll Air Systems, Inc.	Tampa Bay Trane
BID TITLE: Heat Pump Air Conditioners		3711 W. Walnut Street	902 N. Himes Ave.
BID # 08-031-LR		Tampa, FL 33607	Tampa, FL 33609
<b>**Board Meeting 8/21/07**</b>			
ITEM#	DESCRIPTION	UNIT PRICE	UNIT PRICE
AC1	Addison 10 ton Model #DFH 134M 4F-PASCO	\$18,540.00	\$8,422.00
	Mfg / Model #	Addison / DFH 134	Trane / WSC120A4ROA
AC2	Addison 15 ton Model #DFH194L 4F PASCO	\$27,360.00	\$11,812.00
	Mfg / Model #	Addison / DFH 194	Trane / WCD180B400
		<b>REJECT</b>	
		<b>REJECT</b>	
		<b>REJECT</b>	