

District School Board of Pasco County Bid Recommendation

Bid Title	A/C Chemicals Maintenance Department		Number of Vendors Notified	471
Bid Number	11-032-LR		Number of Bids Distributed	26
Date Solicited	July 20, 2010		Number of Vendors Bidding	3
Date Opened	August 31, 2010		Number of Formal "No Bid" Responses	0
Date Board Presentation	October 5, 2010		Funding Source	General
Total Savings	\$18,716.61		Grand Total of Bid	\$10,000.00

Recommendation:

Recommend acceptance of bid from Aquasure, Inc., as noted on attached bid tabulation sheet, as lowest and best, responsive and responsible "all-or-none" bid meeting written specifications.

Term of Contract:

This bid is for chemicals "as needed" by the Maintenance Department for use as a scale/corrosion inhibitor for water-treatment, cooling towers at various schools throughout the District. This is a three-year bid renewable annually based upon mutual agreement of both parties. The first contract period shall be effective from date of Board approval to September 14, 2011.

Notations and Exceptions:

As per the bid specifications, any product that has not been used by the District within the past six (6) years, will be tried at two (2) locations for a 30-day trial period. Should any of these products fail the effectiveness evaluation, the products will be rejected and the next lowest and best, responsive and responsible bidder will be selected. This cycle will continue until a product meets the bid specifications.

Offers from the vendors listed herein are the only offers received timely as of the above opening date and time. All other offers submitted in response to this solicitation, if any, are hereby rejected as late.

Bids Evaluated By:


Rich Graziano, Crew Chief, Maintenance Department
Derek Huston, P.E., Senior Engineer, HSW Engineering, Inc.

Bids Prepared By:

Laurie Roberts, CPPB, Buyer, Purchasing Department

Reviewed and Authorized By:

Kendra Goodman, CPPO, CPPB, Purchasing Agent



DISTRICT SCHOOL BOARD OF PASCO COUNTY BID TABULATION

DATE OF OPENING: August 31, 2010 @ 2:30 PM		American Technical Services of Central Florida, Inc.	Aquasure, Inc.	Aquatech of Florida, Inc.
BID TITLE: A/C Chemicals - Maintenance Dept.		PO Box 16703 Temple Terrace, FL 33687	6201 118th Avenue North Largo, FL 33773	3215-A Fairfield Avenue South St. Petersburg, FL 33712
BID # 11-032-LR				
Board Meeting 10/5/10				
ITEM#	DESCRIPTION	TOTAL PRICE	TOTAL PRICE	TOTAL PRICE
5a	Price Per 55-Gallon Drum	\$710.00	\$499.00	\$474.70 *1519.04
5b	Dilution Ratio for Solution Feed (Amount of Chemical Mixed with Water in 55-Gallon Drum)	5.3 Gal. of C-370A to 49.7 Gal Water per 55 Gal. Drum	5 Gal. + 50 Gal. Water = 55 Gallons	10 Gallons *2.5 Gallons
5c	Dosage Rate Required (Gallons of Undiluted Chemical per Million Gallons of Cooling Water)	35.84 Gallons or 333.33 lbs. at 100 ppm Total Product	23.18 Gallons	63 Gallons *16 Gallons
	*Alternate			